



Mountain Rides Transportation Authority
PO Box 3091
Ketchum, ID 83340
Phone: 208-788-7433

Invitation for Bid

FOR

INSTALLATION OF
ELECTRIC BUS CHARGERS AND DISPENSERS

IFB # 2020-12-001

Addendum #1

December 21, 2020

Question #1**What are the physical dimensions of the chargers?****Answer #1**

See pages 102 and 104 of Appendix D for more details

- i. Chargers – 770mm deep x 1170mm wide x 2030mm high (30.3"x46.1"x79.9")
- ii. Dispensers – 210 mm deep x 600mm wide x 800mm high (8.3"x23.6"x31.5")

Question #2**Do dispensers have to be connected to chargers specified in drawings?****Answer #2**

No, contractor is free to connect dispensers to chargers in most convenient and economical method desired as long as two dispensers are connected to each charger and manufacturer specs are followed.